

TABLE 3B

**WET PENDULUM TEST OR OIL-WET INCLINING PLATFORM
 CLASSIFICATIONS FOR APPLICATIONS WHERE THE NCC DOES NOT
 REQUIRE SLIP RESISTANCE**

| Location | Wet pendulum test | Oil-wet inclining platform test |
|--|--------------------------|--|
| External Pavements and Ramps | | |
| External ramps including sloping driveways, footpaths etc. steeper than 1 in 14 | P5 | R12 |
| External ramps including sloping driveways, footpaths, etc., under 1:14, external sales areas (e.g. markets), external carpark areas, external colonnades, walkways, pedestrian crossings, balconies, verandas, carports, driveways, courtyards and roof decks | P4 | R11 |
| Undercover car parks | P3 | R10 |
| Hotels, Offices, Public Buildings, Schools and Kindergartens | | |
| Entries and access areas including hotels, offices, public buildings, schools, kindergartens, common areas of public buildings, internal lift lobbies | | |
| Wet area | P3 | R10 |
| Transitional area | P2 | R9 |
| Dry area | P1 (see Note 3) | R9 |
| Toilet facilities in offices, hotels and shopping centres | P3 | R10 |
| Hotel apartment bathrooms, en suites and toilets | P2 | A |
| Hotel apartment kitchens and laundries | P2 | R9 |
| Supermarkets and Shopping Centres | | |
| Fast food outlets, buffet food servery areas, food courts and fast food dining areas in shopping centres | P3 | R10 |
| Shop and supermarket fresh fruit and vegetable areas | P3 | R10 |
| Shop entry areas with external entrances | P3 | R10 |
| Supermarket aisles (except fresh food areas) | P1 (see Note 3) | R9 |
| Other separate shops inside shopping centres—wet | P3 | R10 |
| Other separate shops inside shopping centres—dry | P1 (see Note 3) | R9 |
| Loading Docks, Commercial Kitchens, Cold Stores, Serving Areas | | |
| Loading docks under cover and commercial kitchens | P5 | R12 |
| Serving areas behind bars in public hotels and clubs, cold stores and freezers | P4 | R11 |
| Swimming Pools and Sporting Facilities | | |
| Swimming pool ramps and stairs leading to water | P5 | C |
| Swimming pool surrounds and communal shower rooms | P4 | B |
| Communal changing rooms | P3 | A |
| Undercover concourse areas of sports stadiums | P3 | R10 |
| Hospitals and Aged Care Facilities | | |
| Bathrooms and en suites in hospitals and aged care facilities | P3 | B |
| Wards and corridors in hospital and aged care facilities | P2 | R9 |